



AURORA[®] 1050 SERIES AIR SEPARATOR

AURORA® 1050 SERIES

Air Separator

The Air Removal Requirement.

Air is introduced to a hydronic system:

- During initial fill
- While maintaining system pressure
- During routine equipment maintenance
- In a cooling tower operation

Fill water at 50°F (10°C) can hold up to 9% entrained air at 30 psig (207 kPa). When heated up to 200°F (93°C), the water can hold up to 4.5% entrained air. The remaining 4.5% air is released into the system as air pockets, bubbles, and microbubbles, that can negatively impact the performance of fluid flow or heat transfer equipment.


How the Air Separator Removes Air.

Circulating the water through the Air Separator creates a vortex or whirlpool action, sending the heavier air-free water to the outer portion of the tank and allowing the lighter air-entrained water mixture to move into the lower velocity center. At the center of the vortex the air is released from the water, forms bubbles and exits through an air vent or compression tank installed above. Instead of relying entirely on low velocity separation, the Air Separator offers the advantage of efficient separation in a much smaller tank.

The Benefit and Advantage of an Air-Free System.

Air-free water flow means improved systems operation and lower operating costs. The Air Separators eliminate entrained air from heating and cooling systems providing these benefits:


- Allows quick venting of air at start-up
- Reduces annoying noise caused by air entrained in the system
- Reduces service costs due to air-bound piping
- Extends the life of the system by reducing corrosion and erosion
- Improves heat transfer efficiency in boilers, fan coils, chillers, etc.
- Reduces the overall energy costs of your system
- Optimizes pump performance by reducing incidences of 'air lock'




Installation Schematics

Air Separators should be installed at the highest temperature and the lowest pressure points in the system. Where this is not possible, the best location is at the point of highest temperature. Ideally, a separator should be located on the outlet side of the boiler and the suction side of the pump.

For Chiller Applications




For Boiler Applications




Installation Schematics

For Heat Exchanger Applications



Typical Piping Connections to an Air Separator



800 AIRPORT ROAD, NORTH AURORA, ILLINOIS 60542 WWW.AURORAPUMP.COM

Because we are continuously improving our products and services, Pentair reserves the right to change specifications without prior notice.
A-02-1055 01/17/13 © 2013 Pentair Ltd. All Rights Reserved.

