


MAXIMUM CONTROLLER DIMENSION		
FLOW	DEPTH	WIDTH
50-200	16	45
250-400	16	53
450-750	16	60

PART LIST	
LEGEND	DESCRIPTION
1	IN-LINE FIRE PUMP
2	FIRE PUMP CONTROLLER
3	OS&Y GROOVED GATE VALVE WITH TAMPER SWITCH
4	BUTTERFLY ISOLATION VALVE WITH TAMPER SWITCH
5	GROOVED CHECK VALVE
6	SUCTION AND DISCHARGE GAUGES
7	CASING RELIEF VALVE
8	1/2" PRESSURE SENSING LINE
9	SYSTEM MOUNTING STRUCTURAL BASE

NOTES:

1. DIMENSIONS ARE IN INCHES AND MAY VARY  $\pm 1/2"$ .
2. OVERALL DIMENSIONS MAY VARY DEPENDING ON THE CONTROLLER SELECTION BY CUSTOMER.
3. \*\* DIMENSION TABLE VALUES IN PARENTHESES ( ) DENOTE THE PIPE PROJECTION OVERHANGS SKID.
4. STRUCTURAL STEEL BASE TO BE GROUTED ON SITE BY OTHERS.
5. TAMPER SWITCHES TO BE WIRED TO CUSTOMER ALARM BY OTHERS.
6. ALL PIPES ARE OF SCHEDULE 40 STEEL PAINTED RED PER AURORA OR FBN STD 668.
7. ALL PUMP AND PIPING DRAINS TO BE PIPED TO CUSTOMER SUPPLIED DRAIN LOCATION BY OTHERS.
8. REFER TO SPECIFIC CONTROLLER MANUFACTURERS LATEST DIMENSIONAL DRAWINGS FOR ALTERNATE STARTING METHODS AND TRANSFER SWITCH.
9. FOR MAXIMUM CONTROLLER SIZE REFER "MAXIMUM CONTROLLER DIMENSION" TABLE.
10. ALL PIPE AND FITTING CONNECTIONS ARE GROOVED.

					MATERIAL:						
					COMPANY CONFIDENTIAL: Information contained herein is confidential. It is the property of PENTAIR. It is to be used solely for the purpose provided, and it is not to be disclosed to others without the prior written consent of PENTAIR.						
A	ALL	07/28/16	INITIAL RELEASE	SK	VN						
REV	ZONE	DATE	REVISION DESCRIPTION	BY	CK'D						
STANDARD TOLERANCES UNLESS OTHERWISE SPECIFIED											
DO NOT SCALE DRAWING						CPTS FAIRBANKS NUHUIS L-R WITH BYPASS					
						DRAWN BY	DATE	CHECKED BY	APPROVED BY		
						SK	07/28/16	VN	MH		
PLOT SCALE		PATTERN NUMBER		SIZE	PART NUMBER		REV				
1:16		—			295 0039 000		A				